



## DRINKING WATER QUALITY REPORT 2020

150 North Main Street  
PO Box 4177  
Winchester, KY 40392-4177



The Winchester Municipal Utilities (WMU), your drinking water provider, works around the clock to provide exceptional water, wastewater, and solid waste utility services to every consumer. This Drinking Water Quality Report provides you with information regarding your drinking water. For additional information, call WMU at 744-5434.

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Website: [www.wmutilities.com](http://www.wmutilities.com)

### **BACKGROUND INFORMATION ABOUT WMU**

The Winchester Municipal Utilities (WMU) is pleased to provide its Drinking Water Quality Report for 2020. The report is to inform you about the quality of your drinking water and is based on monitoring and test results for the year January 1 through December 31, 2019. Water treatment is a complex and highly regulated activity. WMU strives to continually maintain and improve the quality of its drinking water and many of the other utility services provided to you, our customer.

WMU's raw (untreated) water sources are the Kentucky River (Pool 10) and the Carroll E. Ecton Reservoir, which are surface water sources. The Kentucky River supplied 75% and the Carroll E. Ecton Reservoir supplied 25% of the water treated in 2019. WMU treated 1,613,058,000 gallons of water during 2019 from the Kentucky River and the Carroll E. Ecton Reservoir. The Kentucky River is most vulnerable to contamination from agricultural runoff, which may include pesticides, nutrients and silt from croplands, and substances resulting from the presence of animals on pasture lands. The Carroll E. Ecton Reservoir is most vulnerable to urban storm water runoff, which may include heavy metals from paved areas, nutrients, pesticides and organics (e.g., yard waste) from lawn care. Industrial and construction runoff in urban areas may include silts, synthetic chemicals and metals.

WMU's overall susceptibility to contamination shall be labeled as Moderate. Microbial contaminants, such as Total Coliform, Fecal Coliform, and E Coli are naturally present in the environment, and their presence is tested regularly. Inorganic contaminants, such as copper, fluoride, nitrates, and nitrites are also potential sources of contamination. WMU has a very stringent water sampling program and we take great pride in continuing to ensure our public has the purest drinking water at all hours of the day. All water quality standards are being met by the dedication of our staff and with the assistance of Microbac Laboratories. A complete source water assessment can be obtained or reviewed at WMU, 150 N. Main Street, Winchester, Kentucky.

The water treatment plant has a rated maximum treatment capacity of 6.0 million gallons per day (MGD). WMU operates its water treatment plant 24 hours per day, 365 days per year. The treatment process utilizes conventional flocculation, sedimentation, high-rate filtration, and disinfection.

WMU provides water service to a customer base of 11,873 direct customers and through water sold for resale, to 2,500 customers of the East Clark County Water District and 223 customers of the Kentucky American Water Company. In total, WMU serves 14,562 water customers in Clark County. Future growth, along with increasing regulatory requirements demands that WMU address the potable water supply to continue to provide high quality drinking water to you, our customer.

## SUMMARY OF 2019 WATER QUALITY

WMU routinely monitors for contaminants in your drinking water according to Federal and State regulations. The following table provides the results of our monitoring averages for the period of January 1 through December 31, 2019. Important notes and explanatory definitions are provided at the end of the table.

### DETECTED CONTAMINANTS

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Unless otherwise noted, the report level is the highest level detected.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.							
	Allowable Levels		Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity	
Turbidity (NTU) TT *Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.1	100	No	Soil runoff	
Regulated Contaminant Test Results							
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Inorganic Contaminants							
Barium [1010] (ppm)	2	2	0.0098	0.0098 to 0.0098	Mar-19	No	Drilling wastes; metal refineries; erosion of natural deposits
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.13 (90 <sup>th</sup> percentile)	0.0078 to 0.35	Jun-19	No	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	0.95	0.95 to 0.95	Mar-19	No	Water additive which promotes strong teeth
Lead [1030] (ppb) sites exceeding action level 0	AL = 15	0	1.7 (90 <sup>th</sup> percentile)	0 to 2.2	Jun-19	No	Corrosion of household plumbing systems
Nitrate [1040] (ppm)	10	10	0.72	0.72 to 0.72	Jan-19	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants/Disinfection Byproducts and Precursors							
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.88 (lowest average)	1.03 to 3.06 (monthly ratios)	2019	No	Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.							
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.08 (highest average)	0.2 to 2	2019	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	48 (high site average)	23 to 56 (range of individual sites)	2019	No	Byproduct of drinking water disinfection
TTHM (ppb)(Stage2) [total trihalomethanes]	80	N/A	62 (high site average)	23 to 73 (range of individual sites)	2019	No	Byproduct of drinking water disinfection.

### Unregulated Contaminants (UCMR 4)

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those that EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

Unregulated Contaminants (UCMR4)	Average	Range (ppb)	Date
Manganese	0.137	0 to 0.412	Aug-19
HAA5	49.708	33.6 to 68.3	Jan-20
HAA6Br	6.553	3.93 to 9.67	Jan-20
HAA9	55.983	39.5 to 73	Jan-20

**Note:** January 2020 data is included due to resampling of November 2019 event.

## OTHER TESTS

WMU regularly tests your drinking water for 77 other primary standards, 16 secondary standards, and other standards for which results were found to be within acceptable levels. In order to make this report easier to read and understand, results of those tests are not reported here.

## LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. WMU is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## REPORTING REQUIREMENTS

The United States Environmental Protection Agency (EPA) requires that every water system provide consumers with an annual consumer confidence or water quality report as a result of the Safe Drinking Water Act Amendments of 1996. The report is intended to provide consumers with information regarding the quality of their drinking water and to encourage actions by consumers to protect drinking water supplies. WMU is providing you with this report so that you might be better informed about the quality of your drinking water.

## IMPORTANT DEFINITIONS

### **MCL - Maximum Contaminant Level**

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

### **MCLG - Maximum Contaminant Level Goal**

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

### **MRDL - Maximum Residual Disinfectant Level**

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

### **MRDLG - Maximum Residual Disinfectant Level Goal**

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

### **ND or N/A**

Not detected; does not apply; not available

### **NTU - Nephelometric Turbidity Units**

A measure of water turbidity. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

### **pCi/L - Picocuries per Liter**

A unit of measure of radioactivity.

### **ppm - Parts per Million**

A unit of measure; equal to milligrams per liter (mg/L).

### **ppb - Parts per Billion**

A unit of measure; equal to micrograms per liter (ug/L).

### **Primary Standards**

Mandatory standards established and enforced by EPA and the Kentucky Division of Water that relate to water quality health effects and for which monitoring is required.

### **TT - Treatment Technique**

A required process intended to reduce the level of a contaminant in drinking water.

### **AL - Action Level**

That concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

## WHY ARE THERE CONTAMINANTS IN DRINKING WATER?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

The sources of drinking water; (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before treatment include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. US FDA regulations establish limits for contaminants in bottled water that shall provide the same protection for public health. EPA has determined that drinking water is safe at these levels.

## DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA and the Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

## WATER SYSTEM IMPROVEMENTS

Previous decisions by the WMU and City Commissions have provided for construction of several water large system improvements projects. Construction of a new 9 MGD Water Treatment Plant is the only improvement project not completed as of this date. Construction on the new water treatment plant began in March 2018 and is expected to be completed in July / August 2020. The current contract amount for construction is \$20,331,857. The project is approximately 80% complete.

## CONSENT DECREE

The Consent Decree is the settlement agreement between the United States Environmental Agency (EPA), the Kentucky Energy and Environment Cabinet (EEC, formerly known as the Environmental and Public Protection Cabinet), City and WMU detailing actions to be taken by City and WMU for violations of the Clean Water Act , 33 U.S.C. § 1319. The basic tenants of the Consent Decree call for City and WMU to

- Eliminate existing and recurring sanitary sewer overflows (SSOs)
- Reduce the potential for future SSOs

Such is being achieved through a defined capital program and structured capacity, maintenance, operation, and management (CMOM) program.

During 2019 WMU expended \$210,542.95 on Consent Decree capital projects. Since entry of the Consent Decree in April 2007 WMU has expended \$72,493,602.93 for capital projects to address requirements of the Consent Decree and eliminate I/I.

Calendar year 2019 expenditures for CMOM related activities totaled \$126,170.16. Total cost to-date for development and implementation of WMU's CMOM programs is \$3,311,399.08.



## CAPITAL PROJECTS

Projects under or scheduled for construction include:

New Water Treatment Plant	\$20,331,857
Flanagan/Madison Street Sanitary Sewer Improvements	\$5,289,000
Strodes Creek Solids Processing Facilities Improvements	\$3,000,000
Sylvania Avenue Water Line Replacement	\$130,000

## INFORMATION AND PUBLIC INPUT

If you have questions regarding the information provided in this report or about utility services provided by WMU, please contact WMU (859) 744-5434 or visit WMU's website at [wmutilities.com](http://wmutilities.com). We want you to be informed about the drinking water quality and the utility services provided by WMU.

WMU operates as an enterprise fund of the city of Winchester. Regular public meetings of the WMU Commission are held on the first and third Thursdays of each month at 5:30 p.m. at the WMU administrative offices located at 150 North Main Street, Winchester. The regular meeting agenda for each meeting provides an opportunity for public comment regarding WMU services and operations. The WMU Commission is comprised of local community leaders who are WMU customers and who are very interested in your input. You are invited to avail yourself of this opportunity for public input.



New Lower Howards Creek Water Treatment Plant  
Under Construction - May 2019